

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0694:207 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Fire Control Instruments, 301 2<sup>nd</sup> Avenue, Waltham, MA 02451-1133  
Contact: Anthony J. Shalna (781) 471-3000

**DESIGN:** Models P1215, P121575, \*P2415, \*P241575, P2430, P2475, P24110 horn/strobes  
\*with suffix -FC, also with or without suffix -W (white color). Model P241575 may also have \*suffix -F for FUEGO design, \*suffix EV for EVAC, and \*suffix AG for AGENT. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Electrical:	-12:	10.5 - 17 VDC
	-24:	20 - 30 VDC
Candela:	-15:	15 cd
	-1575:	15 cd, 75 cd on axis
	*-30:	30 cd
	-75:	75 cd
	-110:	110 cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. These sounder/strobe combination units are not intended for field assembly.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as horn strobes for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application. For wall mount and indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturers Installation Manual for details.

**NOTE:** Models P1215-FC, P1215W-FC, P121575-FC and P121575W-FC are NOT intended for Public Mode Fire Alarm Service when used on 12 V control panel at low volume.

**XLF:** 7135-1209:173

\*Rev 06-16-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**  
*Program Manager*